

## II. DEFINITIONS.

Definitions not found in this section, are located in ch. Comm 81 of the Wisconsin Administrative Code or the terms use the standard dictionary definition.

A. “Cobbles” means rock fragments greater than 3 inches, but less than 10 inches in diameter.

B. “Service provider” means the individual or company that is responsible for managing and maintaining the holding tank system.

C. “Stones” means rock fragments greater than 10 inches in diameter, but less than 24 inches.

## III. DESCRIPTION AND PRINCIPLE OF OPERATION.

The POWTS holding tank serves to contain wastewater or sewage on site until the contents is pumped and hauled to a proper point of disposal. Pumping and monitoring reports are submitted to the department or designated agent.

The holding tank installed under this component manual holds domestic wastewater, stormwater or clearwater inclusions permitted under s. Comm 82.36, Wis. Adm. Code, and/or human excrement until pumped by an individual licensed under NR 113, Wis. Adm. Code.

Industrial wastewater is regulated by the Department of Natural Resources (DNR), and is not included in this specification, unless approved by the DNR in advance.

See figure 1, for a typical holding tank design.

